

REQUEST FOR MATERIAL APPROVAL

MAR No.: A R KCT532-HBS-MAR-A-0333

Rev. 0 0

Date: 1 8 0 5 2 0 1 7

Project Title	: Panorama Residences & Suites, Abraj Quartier Tower AQ-07 and Town Houses	Client / Owner	: First Qatar Real Estate Development Co.
Contract Title / No.	:	PMCS Consultant	: Projacs International Project Management
Prepared By	: Engr. Maher Etloom	Contractor	: Al Khayyat Contracting and Trading

MAR Ref. No.: KCT532-HBS-MAR-A-0333 Rev. 00

Specification Ref.: Technical Specification, Part 4 – Acoustic Report & Value Engineering Annexure - 4

Drawing Ref.: K-532-532-15-Pr-A-Q-7
CONTROLLED COPY
2/2

BOQ Ref.:



Discipline/s:

- Architectural Civil/Structural Electrical Mechanical Landscape General
 Infrastructure Audio / Video Instruments / Control Utilities IT Others:-----

Item No.	Material Description	Notes
01.	Acoustic Underlay on Top RC Slabs (under screed)	

Subcontractor:	HILLPOINT BUILDING SOLUTIONS
Manufacturer / Supplier:	Mappy – Italy / Hillpoint-Qatar
Cost Impact:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Time Impact:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Enclosure:	<input checked="" type="checkbox"/> Sample <i>2 Pcs</i> <input checked="" type="checkbox"/> Data Sheet <input checked="" type="checkbox"/> Catalogue <input checked="" type="checkbox"/> Specification Comparison Sheet <input checked="" type="checkbox"/> Others (Test Report)

For Contractor Signature

TRF-4876

Technical Manager			Project Director		
Name	Signature	Date	Name	Signature	Date
Mr. Ali Hassan Kalakech	<i>[Signature]</i>	<i>18/05/17</i>	Nidal Youssef Hussein	<i>[Signature]</i>	<i>18.05.2017</i>

Previous Submittal Revision Status (if applicable)
 A- Approved B- Approved As Noted C-Rejected I-For Information

For PMCS Signature

Comments (refer to attached sheet for additional comments, if any)

ACCEPTED SUBJECT TO THE FOLLOWING:
 1- CONFIRM THICKNESS OF PROPOSED MATERIAL AS IT IS MENTIONED 5mm & 6mm IN COMPLIANCE SHEET.
 2- CONFIRM TEST RESULTS ARE THE SAME USING PORCELAIN TILES AS FLOOR FINISH.
 3- CONFIRM MATERIAL USED IN SIMILAR PROJECTS - PROVIDE LIST
23-05-2017
 Current Submittal Status: *REFER TO ATTACHED REQUEST OF ALTERNATIVE OR SUBSTITUTION # RFA-A-003 WITH CLIENT'S APPROVAL*
 A- Approved B- Approved As Noted C-Rejected I-For Information

<i>23/5</i> Enab M. Project Manager	<i>[Signature]</i> Signature	<i>19.06.17</i> Date
---	---------------------------------	-------------------------

DISTRIBUTION LIST

Originals	Date	Signature	Copies	Date	Signature
<input type="checkbox"/> Employer/Engineer			<input type="checkbox"/> PMCS		
<input type="checkbox"/> Contractor			<input type="checkbox"/> Others		

